

**CLARIFICATION FOR SUPPLY AND INSTALL OF AIR MANAGEMENT SYSTEM -
TCB/TASP II/2015-16/SUP/01**

Question No 1:

The specified cooling capacity of the air conditioning is indicated as 20.1 kW. The total airflow indicated is 0.3 m³/s.

It is not possible to select a unit that complies with these parameters. The minimum airflow for a 20 kW cooling unit would be in the region of 1.6 to 1.8 m³/s. Please advice.

Reply:

The important issue is that; the cooling capacity should achieve 20Kw and the flow rate should not be less than 0.3m³/s, for that matter you can quote 1.6m³/s to 1.8m³/s as mentioned

Date: 4 May, 2016